

GL SpectroSoft Report  
Lighting Research & Measurement Center


Measurement name: B3758\_F\_20230907\_R\_S  
Measurement time: 2023-09-07T07:58:23  
Report time: 2023-09-13  
Device: GL SPECTIS 1.0 Touch + Flicker  
Sensor Temperature: 28.16°C

Client name: LED line LITE  
Model name: Światłówka LED T8 9W 6500K 900lm  
220-240V 60cm  
Item No: 202016  
Serial No.: 21405  
Made by: Radosław Kośnik

## Flicker

Flicker	100 Hz
Flicker index	0.002064
Flicker percent	1.08 %
SVM	0.0035

## Flicker chart



## FFT chart

