

GL SpectroSoft Report
Lighting Research & Measurement Center


Measurement name: B3759_F_20230907_M_S
Measurement time: 2023-09-07T13:28:34
Report time: 2023-09-13
Device: GL SPECTIS 1.0 Touch + Flicker
Sensor Temperature: 28.91°C

Client name: LED line PRIME
Model name: świetlówka LED T8 22W 6500K 3300lm
220-240V 150cm
Item No: 202115
Serial No.: 21405
Made by: Radosław Kośnik

Flicker

Flicker	100 Hz
Flicker index	0.005388
Flicker percent	2.43 %
SVM	0.0572

Flicker chart



FFT chart

