

GL SpectroSoft Report
Lighting Research & Measurement Center


Measurement name: B5374_F_20250917_M_S
Measurement time: 2025-09-17T01:18:42
Report time: 2025-09-19
Device: GL SPECTIS 1.0 Touch + Flicker
Sensor Temperature: 25.71°C

Client name: LED line LITE
Model name: Światłówka LED NANO T8 G13 6500K
18W 1820lm 230V 270° 120cm PC LITE
Item No: 216754
Serial No.: 05403
Made by: Radosław Kośnik

Flicker

Flicker	100 Hz
Flicker index	0.000817
Flicker percent	0.59 %
SVM	0.0015

Flicker chart



FFT chart

