

GL SpectroSoft Report
Lighting Research & Measurement Center


Measurement name: B5375_F_20250917_M_S
Measurement time: 2025-09-17T22:01:47
Report time: 2025-09-19
Device: GL SPECTIS 1.0 Touch + Flicker
Sensor Temperature: 25.05°C

Client name: LED line LITE
Model name: Światłówka LED NANO T8 G13 6500K
9W 900lm 230V 270° 60cm PC LITE
Item No: 216778
Serial No.: 05403
Made by: Radosław Kośnik

Flicker

Flicker	100 Hz
Flicker index	0.001945
Flicker percent	1.15 %
SVM	0.0065

Flicker chart



FFT chart

