

GL SpectroSoft Report  
Lighting Research & Measurement Center


Measurement name: B5419\_F\_20000105\_M\_S  
Measurement time: 2000-01-05T15:51:43  
Report time: 2025-10-22  
Device: GL SPECTIS 1.0 Touch + Flicker  
Sensor Temperature: 25.99°C

Client name: LED line PRIME  
Model name: HighBay Seron 200/160/120W 4000K  
28000lm 120° PRIME  
Item No: 219694  
Serial No.: 12210  
Made by: Radosław Kośnik

## Flicker

Flicker	100 Hz
Flicker index	0.000902
Flicker percent	0.65 %
SVM	0.0077

## Flicker chart



## FFT chart

